

CHEM-AQUA

CORE STRATEGIES FOR MANAGING BIOFILMS & LEGIONELLA RISK

4

Monitor Results

Monitor and maintain appropriate disinfectant residuals.



4. Monitor Results


3

Routine Circulation

Minimize stagnation by routinely circulating biocide treated water through off-line equipment and piping to manage biofilm formation.



3. Routine Circulation



1. Clean and Disinfect

1

Clean and Disinfect

Routine cleaning and disinfection is essential system maintenance. Adding Chem-Aqua's patented [bioeXile®](#) solution to disinfection protocols dramatically improves biofilm removal and control.



2. Regulate Temperature

2

Regulate Temperatures

Keep hot systems hot and cold systems cold. Boilers should be maintained at a temperature of 160° or higher. Cooling systems should be maintained at ...